

RIFERIMENTI
SOCIETA': SIPEA SRL
CODICE STABILIMENTO: LTC1
RIVAROLO CANAVESE (TO)
Corso Indipendenza, 53



CALDAIA BIOMASSA - EMISSIONI IMPIANTO DEL 2016/02/14

CODICE	CO R 021	COT R 057	NOX NO2 R 027	SO2 R 026	PLV R 022	TF 051	QFS 055
CAMPO SCALA	0-500 mg/Nm3	0-60 mg/Nm3	0-600 mg/Nm3	0-400 mg/Nm3	0-60 mg/Nm3	0-300 -C	0-54263 Nm3/h
LIMITE GIORNALIERO	150 mg/Nm3		300 mg/Nm3				
VALORE MIN-MAX	8.8-34.8	0.0-0.1	83.2-126.0	0.0-0.0	0.0-2.1	142.1-148.5	31329.6-34515.0
MEDIA GIORNALIERA	20	0	101.9	0	0.1	144.9	32989.9
SUPERO LIMITE GIORNALIERO	NO	NO	NO	NO	NO	NO	NO

CALDAIA METANO - EMISSIONI IMPIANTO DEL 2016/02/14

CODICE	CO R 021	TF051
--------	----------	-------

CAMPO SCALA		
LIMITE GIORNALIERO		
VALORE MIN-MAX		
MEDIA GIORNALIERA		
SUPERO LIMITE GIORNALIERO		

DATI VERIFICATI DA: 

RESPONSABILE IMPIANTO: 