

<b>RIFERIMENTI</b>	
SOCIETA': SIPEA SRL	
CODICE STABILIMENTO: LTC1	
RIVAROLO CANAVESE (TO) Corso Indipendenza, 53	

### CALDAIA BIOMASSA - EMISSIONI IMPIANTO DEL 2016/02/02

CODICE	CO R 021	COT R 057	NOX NO2 R 027	SO2 R 026	PLV R 022	TF 051	QFS 055
<b>CAMPO SCALA</b>	0-500 mg/Nm3	0-60 mg/Nm3	0-600 mg/Nm3	0-400 mg/Nm3	0-60 mg/Nm3	0-300 -C	0-54263 Nm3/h
<b>LIMITE GIORNALIERO</b>	150 mg/Nm3		300 mg/Nm3				
<b>VALORE MIN-MAX</b>	6.2-49.8	0.0-0.4	70.0-160.8	0.0-0.0	0.0-2.2	138.8-148.3	31383.5-34215.8
<b>MEDIA GIORNALIERA</b>	23.4	0.1	98.7	0	0.1	143.2	32536.6
<b>SUPERO LIMITE GIORNALIERO</b>	NO	NO	NO	NO	NO	NO	NO

### CALDAIA METANO - EMISSIONI IMPIANTO DEL 2016/02/02

CODICE	CO R 021	TF051
--------	----------	-------

<b>CAMPO SCALA</b>		
<b>LIMITE GIORNALIERO</b>		
<b>VALORE MIN-MAX</b>		
<b>MEDIA GIORNALIERA</b>		
<b>SUPERO LIMITE GIORNALIERO</b>		

DATI VERIFICATI DA: 

RESPONSABILE IMPIANTO: 