


|                                                  |                                                                                     |
|--------------------------------------------------|-------------------------------------------------------------------------------------|
| <b>RIFERIMENTI</b>                               |  |
| SOCIETA': SIPEA SRL                              |                                                                                     |
| CODICE STABILIMENTO: LTC1                        |                                                                                     |
| RIVAROLO CANAVESE (TO)<br>Corso Indipendenza, 53 |                                                                                     |

| CALDAIA BIOMASSA - EMISSIONI IMPIANTO DEL 2016/02/20 |              |             |               |              |             |             |                 |
|------------------------------------------------------|--------------|-------------|---------------|--------------|-------------|-------------|-----------------|
| CODICE                                               | CO R 021     | COT R 057   | NOX NO2 R 027 | SO2 R 026    | PLV R 022   | TF 051      | QFS 055         |
| CAMPO SCALA                                          | 0-500 mg/Nm3 | 0-60 mg/Nm3 | 0-600 mg/Nm3  | 0-400 mg/Nm3 | 0-60 mg/Nm3 | 0-300 -C    | 0-54263 Nm3/h   |
| LIMITE GIORNALIERO                                   | 150 mg/Nm3   |             | 300 mg/Nm3    |              |             |             |                 |
| VALORE MIN-MAX                                       | 7.5-50.6     | 0.0-0.4     | 102.3-166.6   | 0.0-0.0      | 0.0-0.0     | 141.3-147.2 | 32998.9-35883.0 |
| MEDIA GIORNALIERA                                    | 20.1         | 0.1         | 122.9         | 0            | 0           | 144.3       | 34533.8         |
| SUPERO LIMITE GIORNALIERO                            | NO           | NO          | NO            | NO           | NO          | NO          | NO              |

| CALDAIA METANO - EMISSIONI IMPIANTO DEL 2016/02/20 |          |       |
|----------------------------------------------------|----------|-------|
| CODICE                                             | CO R 021 | TF051 |

|                           |  |  |
|---------------------------|--|--|
| CAMPO SCALA               |  |  |
| LIMITE GIORNALIERO        |  |  |
| VALORE MIN-MAX            |  |  |
| MEDIA GIORNALIERA         |  |  |
| SUPERO LIMITE GIORNALIERO |  |  |

DATI VERIFICATI DA: 

RESPONSABILE IMPIANTO: 