

|                           |
|---------------------------|
| <b>RIFERIMENTI</b>        |
| SOCIETA': SIPEA SRL       |
| CODICE STABILIMENTO: LTC1 |
| RIVAROLO CANAVESE (TO)    |
| Corso Indipendenza, 53    |



### CALDAIA BIOMASSA - EMISSIONI IMPIANTO DEL 2016/02/25

| CODICE                    | CO R 021     | COT R 057   | NOX NO2 R 027 | SO2 R 026    | PLV R 022   | TF 051      | QFS 055         |
|---------------------------|--------------|-------------|---------------|--------------|-------------|-------------|-----------------|
| CAMPO SCALA               | 0-500 mg/Nm3 | 0-60 mg/Nm3 | 0-600 mg/Nm3  | 0-400 mg/Nm3 | 0-60 mg/Nm3 | 0-300 -C    | 0-54263 Nm3/h   |
| LIMITE GIORNALIERO        | 150 mg/Nm3   |             | 300 mg/Nm3    |              |             |             |                 |
| VALORE MIN-MAX            | 12.5-88.6    | 0.0-1.1     | 70.8-119.2    | 0.0-0.0      | 0.0-0.0     | 137.8-146.3 | 32040.0-34920.5 |
| MEDIA GIORNALIERA         | 34.4         | 0.2         | 95.4          | 0            | 0           | 143.4       | 33203.7         |
| SUPERO LIMITE GIORNALIERO | NO           | NO          | NO            | NO           | NO          | NO          | NO              |

### CALDAIA METANO - EMISSIONI IMPIANTO DEL 2016/02/25

| CODICE | CO R 021 | TF051 |
|--------|----------|-------|
|--------|----------|-------|

|                           |  |  |
|---------------------------|--|--|
| CAMPO SCALA               |  |  |
| LIMITE GIORNALIERO        |  |  |
| VALORE MIN-MAX            |  |  |
| MEDIA GIORNALIERA         |  |  |
| SUPERO LIMITE GIORNALIERO |  |  |

DATI VERIFICATI DA: 

RESPONSABILE IMPIANTO: 