

|                                                  |                                                                                     |
|--------------------------------------------------|-------------------------------------------------------------------------------------|
| <b>RIFERIMENTI</b>                               |  |
| SOCIETA': SIPEA SRL                              |                                                                                     |
| CODICE STABILIMENTO: LTC1                        |                                                                                     |
| RIVAROLO CANAVESE (TO)<br>Corso Indipendenza, 53 |                                                                                     |

### CALDAIA BIOMASSA - EMISSIONI IMPIANTO DEL 2016/02/09

| CODICE                    | CO R 021     | COT R 057   | NOX NO2 R 027 | SO2 R 026    | PLV R 022   | TF 051      | QFS 055         |
|---------------------------|--------------|-------------|---------------|--------------|-------------|-------------|-----------------|
| CAMPO SCALA               | 0-500 mg/Nm3 | 0-60 mg/Nm3 | 0-600 mg/Nm3  | 0-400 mg/Nm3 | 0-60 mg/Nm3 | 0-300 -C    | 0-54263 Nm3/h   |
| LIMITE GIORNALIERO        | 150 mg/Nm3   |             | 300 mg/Nm3    |              |             |             |                 |
| VALORE MIN-MAX            | 12.7-73.2    | 0.0-2.7     | 73.1-124.8    | 0.0-0.5      | 0.0-2.2     | 140.6-148.8 | 32451.8-35615.1 |
| MEDIA GIORNALIERA         | 42.4         | 0.4         | 94.9          | 0            | 0.1         | 144.6       | 34359           |
| SUPERO LIMITE GIORNALIERO | NO           | NO          | NO            | NO           | NO          | NO          | NO              |

### CALDAIA METANO - EMISSIONI IMPIANTO DEL 2016/02/09

| CODICE | CO R 021 | TF051 |
|--------|----------|-------|
|--------|----------|-------|

|                           |  |  |
|---------------------------|--|--|
| CAMPO SCALA               |  |  |
| LIMITE GIORNALIERO        |  |  |
| VALORE MIN-MAX            |  |  |
| MEDIA GIORNALIERA         |  |  |
| SUPERO LIMITE GIORNALIERO |  |  |

DATI VERIFICATI DA: 

RESPONSABILE IMPIANTO: 